

This translation has been made based on the original collections of the interpretation by JISCBA

January 26, 2007
Revised on September 2, 2009

[Common 3] Handling of long-lasting test items

Question:

With regard to the long-lasting tests such as 8760 hours hot internal pressure creep tests related to cross-linked polyethylene pipes etc., and 6000 hours weatherability tests of synthetic resin-coated iron wires , is it possible to use the past data since they are the type approval test item and tested at the initial stage of design?

Interpretation:

Carry out the test as specified, even for long-lasting test

End of text