

JIS

JAPANESE
INDUSTRIAL
STANDARD

Translated and Published by
Japanese Standards Association

JIS A 1517 : 2020

(JSMA/JSA)

**Windows and doorsets — Watertightness
test under dynamic pressure**

ICS 91.060.50

Reference number : JIS A 1517 : 2020 (E)

PROTECTED BY COPYRIGHT

11 S

A 1517 : 2020

Date of Establishment: 1984-02-01

Date of Revision: 2020-02-20

Date of Public Notice in Official Gazette: 2020-02-20

Investigated by: Japanese Industrial Standards Committee
Standards Board for ISO area
Technical Committee on Architecture

JIS A 1517 : 2020, First English edition published in 2021-03

Translated and published by: Japanese Standards Association
Mita MT Building, 3-13-12, Mita, Minato-ku, Tokyo, 108-0073 JAPAN

In the event of any doubts arising as to the contents,
the original JIS is to be the final authority.

© JSA 2021

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

Printed in Japan

HT/HN

PROTECTED BY COPYRIGHT

Contents

		Page
Introduction	1
1	Scope	1
2	Normative reference	1
3	Terms and definitions	1
4	Test apparatus	2
5	Specimen and specimen attaching rig	3
5.1	Specimen	3
5.2	Specimen attaching rig	4
6	Test method	4
6.1	Installation of specimen	4
6.2	Test environment	4
6.3	Test procedure	4
7	Recording of results	6
8	Test report	6
Annex JA (informative)	Comparison table between JIS and corresponding International Standard	8
Annex JB (informative)	Comparison table between previous and current editions of this Standard on technically significant revisions	12

Foreword

This Japanese Industrial Standard has been revised by the Minister of Economy, Trade and Industry through deliberations at the Japanese Industrial Standards Committee as the result of proposal for revision of Japanese Industrial Standard submitted by Japan Sash Manufacturers Association (JSMA)/Japanese Standards Association (JSA) with a draft being attached, based on the provision of Article 12, paragraph (1) of the Industrial Standardization Act applied mutatis mutandis pursuant to the provision of Article 16 of the said Act. This edition replaces the previous edition (**JIS A 1517:1996**), which has been technically revised.

This **JIS** document is protected by the Copyright Law.

Attention is drawn to the possibility that some parts of this Standard may conflict with patent rights, published patent application or utility model rights. The relevant Minister and the Japanese Industrial Standards Committee are not responsible for identifying any of such patent rights, published patent application or utility model rights.

NOTE Based on Article 9 of the Supplementary Provisions to the Unfair Competition Prevention Act etc., any submission of proposal, or employment of procedures such as deliberation by the Japanese Industrial Standards Committee under the previous Industrial Standardization Act shall be deemed to have been conducted pursuant to the provision of Article 12, paragraph (1) of the revised Industrial Standardization Act.

Windows and doorsets — Watertightness test under dynamic pressure

Introduction

This Japanese Industrial Standard has been prepared based on **ISO 15821** : 2007, Edition 1, with some modifications of the technical contents to reflect the conditions unique to Japan.

The vertical lines on both sides and dotted underlines indicate changes from the corresponding International Standard. A list of modifications with the explanations is given in Annex JA. The comparison table between previous and current editions of this Standard on technically significant revisions is given in Annex JB.

1 Scope

This Standard specifies the method for testing water tightness of windows and doorsets using a pressure chamber, among other test items specified in **JIS A 1513**.

NOTE The International Standard corresponding to this Standard and the symbol of degree of correspondence are as follows.

ISO 15821 : 2007 *Doorsets and windows — Water-tightness test under dynamic pressure — Cyclonic aspects* (MOD)

In addition, symbols which denote the degree of correspondence in the contents between the relevant International Standard and **JIS** are IDT (identical), MOD (modified), and NEQ (not equivalent) according to **ISO/IEC Guide 21-1**.

2 Normative reference

The following standard contains provisions which, through reference in this text, constitute provisions of this Standard. The most recent edition of the standard (including amendments) indicated below shall be applied.

JIS A 1513 *Windows and doorsets — General rule for test method*

3 Terms and definitions

For the purpose of this Standard, the following terms and definitions apply.

3.1

water tightness

ability of a window or doorset to resist water penetration into the indoor side under wind and rain condition

3.2

water penetration