

JIS

JAPANESE INDUSTRIAL STANDARD

Warm air furnaces

JIS A 4003—1995

Translated and Published

by

Japanese Standards Association

**In the event of any doubt arising,
the original Standard in Japanese is to be final authority**

Errata for JIS (English edition) are printed in *Standardization Journal*, published monthly by the Japanese Standards Association.

Errata will be provided upon request, please contact:

**Business Department,
Japanese Standards Association**
4-1-24, Akasaka, Minato-ku,
Tokyo, JAPAN 107
TEL. 03-3583-8002
FAX. 03-3583-0462

Errata are also provided to subscribers of JIS (English edition) in *Monthly Information*.

JAPANESE INDUSTRIAL STANDARD

J I S

Warm air furnaces

A 4003-1995

1. Scope This Japanese Industrial Standard specifies warm air furnaces with a rated heating capacity not less than 18.6 kW {16000 kcal/h} employing kerosine, fuel oil, town gas or liquefied petroleum gas as the fuel and mainly used for heating. However, space heaters specified in JIS S 2039 and JIS S 2122 are excluded.

Remarks 1. The standards cited in this Standard are shown in Attached Table 1.

2. The units and numerical values in { } in this Standard are based on the traditional units and are appended for informative reference.

2. Definitions For the purpose of this Standard, in addition to the definitions specified in JIS B 0113, and JIS S 2091, the following principal definitions apply.

(1) gas duct A path which leads the flue gas from the heat exchanger to the exhaust pipe or chimney in a warm air furnace.

(2) chimney A path through which flue gas is exhausted outdoors which has a rising part and on which draft effect can be expected.

(3) non-ignition Such a phenomenon that the fuel is not ignited in the igniting operation.

(4) dew formation Such an atmospheric phenomenon that the temperature of air or flue gas which comes in contact with the surface of a cool substance decreases and water drops are formed due to condensation of water vapor when the humidity at that part becomes 100 %.

3. Classification and symbolization Warm air furnaces are classified in accordance with the type and the fuel to be used, and symbolized as stated below.

3.1 Classification by type The classification by type shall be as stated in Table 1.

Table 1. Classification by type

| Type | Symbol | Informative reference |
|---|--------|-----------------------|
| Direct blow-out type | P | Attached Fig. 1 |
| Duct connection type with built-in blower | D | Attached Fig. 2 |
| Duct connection type with separate blower | S | Attached Fig. 3 |