



JAPANESE
INDUSTRIAL
STANDARD

Translated and Published by
Japanese Standards Association

JIS B 7563 : 2021

(JMA/JSA)

Electronic digital-indicator gauge

B 7563 : 2021

Date of Establishment: 2021-01-20

Date of Public Notice in Official Gazette: 2021-01-20

Investigated by: Japanese Industrial Standards Committee
Standards Board for ISO area

JIS B 7563 : 2021, First English edition published in 2022-02

Translated and published by: Japanese Standards Association
Mita MT Building, 3-13-12, Mita, Minato-ku, Tokyo, 108-0073 JAPAN

In the event of any doubts arising as to the contents,
the original JIS is to be the final authority.

© JSA 2022

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

Printed in Japan

HT/HN

PROTECTED BY COPYRIGHT

Contents

	Page
Introduction	1
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Design specification (design characteristics)	4
4.1 General	4
4.2 Nomenclature	4
4.3 Retention of an electronic digital-indicator gauge	5
4.4 Dimensions	6
4.5 Digital indicating display	7
4.6 Error messages	7
4.7 Interface	7
4.8 Protection for field use	7
4.9 Contact element	7
4.10 Zero adjustment	8
4.11 Additional functions	8
4.12 Pre-span and post-span	8
4.13 Design specification by the manufacturer (or the supplier)	8
5 Performance (metrological characteristics)	8
5.1 Maximum permissible error (MPE) and maximum permissible limit (MPL)	8
5.2 Measuring forces	9
6 Marking in product documentation	10
7 Proving of conformance with specification	10
7.1 General	10
7.2 Measurement method and evaluation method	10
7.3 Transferring zero method by data processing	10
7.4 Standard reference temperature	10
8 Marking	11
Annex JA (normative) Measurement method and evaluation method of per- formance (metrological characteristics)	12
Annex JB (informative) Example of a diagram of errors of indication	14
Annex JC (informative) Transferring zero method (performance evaluation method by data processing)	15

Annex JD (informative)	Example data sheet for design and performance specifications	18
Annex JE (informative)	Marking in product documentation	19
Annex JF (informative)	Comparison table between JIS and corresponding International Standard	20

Foreword

This Japanese Industrial Standard has been established by the Minister of Economy, Trade and Industry through deliberations at the Japanese Industrial Standards Committee according to the proposal for establishment of Japanese Industrial Standard submitted by Japan Precision Measuring Instruments Manufacturers Association (JMA)/Japanese Standards Association (JSA) with a draft being attached, based on the provision of Article 12, paragraph (1) of the Industrial Standardization Act.

This **JIS** document is protected by the Copyright Act.

Attention is drawn to the possibility that some parts of this Standard may conflict with patent rights, published patent application or utility model rights. The relevant Minister and the Japanese Industrial Standards Committee are not responsible for identifying any of such patent rights, published patent application or utility model rights.

Blank

Electronic digital-indicator gauge

Introduction

This Japanese Industrial Standard has been prepared based on **ISO 13102** : 2012, Edition 1, with some modifications of the technical contents to make it rationality suitable for the actual situation of manufacturing industries and application.

The vertical lines on both sides and dotted underlines indicate changes from the corresponding International Standard. A list of modifications with the explanations is given in Annex JF.

1 Scope

This Japanese Industrial Standard specifies the design specification (design characteristics) and performance (metrological characteristics) of electronic digital-indicator gauges with a minimum digital step of 0.01 mm, 0.001 mm and 0.000 5 mm.

NOTE The International Standard corresponding to this Standard and the symbol of degree of correspondence are as follows.

ISO 13102 : 2012 *Geometrical product specifications (GPS) — Dimensional measuring equipment: Electronic digital-indicator gauge — Design and metrological characteristics* (MOD)

In addition, symbols which denote the degree of correspondence in the contents between the relevant International Standard and **JIS** are IDT (identical), MOD (modified), and NEQ (not equivalent) according to **ISO/IEC Guide 21-1**.

2 Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this Standard. The most recent editions of the standards (including amendments) indicated below shall be applied.

JIS B 0641-1 *Geometrical Product Specifications (GPS) — Inspection by measurement of workpieces and measuring equipment — Part 1 : Decision rules for proving conformance or nonconformance with specifications*

NOTE Corresponding International Standard : **ISO 14253-1** *Geometrical product specifications (GPS) — Inspection by measurement of workpieces and measuring equipment — Part 1 : Decision rules for verifying conformity or non-conformity with specifications*

JIS B 0642 *Geometrical product specifications (GPS) — General concepts and requirements for GPS measuring equipment*

NOTE Corresponding International Standard : **ISO 14978** *Geometrical product specifications (GPS) — General concepts and requirements for GPS*